DEPARTMENT OF UTILITIES
NICHOLAS GORNICK
PHONE: 815/724-3675
FAX: 815/724-3620
ngornick@joleitcity.org

CITY OF JOLIET
ADDENDUM NO. 2

WESTSIDE WASTEWATER TREATMENT PLANT HIGH MAST LIGHTING UPGRADES
CONTRACT NO. 2667-1022

TO: PROSPECTIVE BIDDERS

THE ATTENTION OF ALL PROSPECTIVE BIDDERS ON THE ABOVE REFERENCED PROJECT IS CALLED TO THE FOLLOWING QUESTIONS AND ANSWERS IN REGARDS TO THE SPECIFICATIONS;

1. We were hoping to include the available ComEd Energy Efficiency Program incentives into our bid price.
    a. All bids should be tabulated without the anticipation of incentives. After the bid is awarded an application for any qualifying incentives will be submitted.
2. An alternate product was submitted for consideration.
    a. The following product is acceptable;

Manufacturer: Solarmax LED, Inc.
Model: 460WiNM-HV-L5-4070-00-T502-X-FA

- Watt: 460
- Lumens: 75,535
- Voltage: 347-480 VAC
- CCT & CRI: 4000K, CRI 70+
- Color: Custom
- Distribution: Type V
- Options: Field Adjustment
- Mount: Arm Mount

Warranty: 7 years

PROSPECTIVE BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THE APPROPRIATE ADDENDUM NUMBER(S) BY STATING THIS ON THE OUTSIDE OF THE SEALED ENVELOPE CONTAINING THE BID PROPOSAL FOR THE ABOVE MENTIONED CONTRACT. FURTHER, BID PROPOSALS SHALL NOT BE OPENED WITHOUT ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS FOR THE GIVEN CONTRACT.

_____
Nicholas C. Gornick
Project Manager